

# Generators (Permanent/Standby)

**Permit Fees:** \$ 75.00 (includes C/C fee) **Please remember to call the Building Department at (585) 617-6195 for Final Inspection after installation**

**The following are required for standby generators installed in the Town of Ogden and Village of Spencerport.**

Please note that residences serviced by Spencerport Municipal Electric may have additional requirements as noted.

## **Permit Requirements:**

- All installations for standby generators within the Town of Ogden and Village of Spencerport require a Building Permit;
- Instrument Survey Map of subject property showing location of proposed generator;
- Copy of manufacturers installation manual shall be presented at time of application;
- Standby generator shall be located 3 feet minimum from house and from any Electric meter, and 5 feet minimum from any Gas meter, and from any operable window; (generators may be placed closer than 3', excluding meters & windows, if unit has approvals that meet the NY State 2015 Code NFPA 37, Section 4.1.4 standards)
- Approval (Job #) from Rochester Gas & Electric for Rochester Gas & Electric natural gas patrons shall be provided at time of application;
- Proper grounding and metering cabinets to be upgraded as may be necessary to satisfy current underwriter requirements;
- Spencerport Municipal Electric does not allow the cutting and removal of meter seals or meter removal by installers/electricians;
- Spencerport Municipal Electric Inspector and/or Building Inspector shall inspect the installation upon completion;
- All meters shall be labeled with a notification that standby power has been installed;
- Upon completion of installation, a (Town of Ogden approved) same day UL inspection agency shall inspect and certify the compliance of the installation; **Note:** Spencerport Municipal Electric recognizes Middle Department only.
- LP gas fueled generators shall be coordinated with local suppliers if natural gas is not available (2 cylinders not to exceed 150 pounds);
- All installations must comply with Article 700 of National Electrical Code. Generation shall not be connected to building wiring without an approved isolating double-pole, double-throw "Break before make" switch.

Town of Ogden \* Building Department \* 269 Ogden Center Road, Spencerport, NY 14559  
[www.ogdenny.com](http://www.ogdenny.com) \* (585) 617-6195 \* (585) 352-4590 fax